

### Thermal and Electrical Power for Beyond-Grid Applications Session

**Session Lead: Tyler Westover** 

Al Wilson Sargent & Lundy


- Summary of Thermal Energy Extraction Studies
  - 30, 50, 70% Thermal Extraction- Sargent & Lundy A/E,

Thomas Ulrich INL


rich • Plant Operations Testing – Collaboration with Westinghouse Electric Company & GSE Systems








Levelized Cost of Hydrogen is competitive for markets that value alternative energy products, power, fuels, chemicals, steel.



- DOE's goal is to produce hydrogen for less than \$2 per kg by 2026
- This goal can be met 95% of the year with LWRs that are dedicated to producing hydrogen.

### Preconceptual Designs for Coupling a Pressurized-Water Reactors with a High Temperature Electrolysis Hydrogen Production Plant

- Developed preconceptual designs to couple a pressurized water reactor (PWR) to different high temperature electrolysis (HTE) hydrogen plants.
  - These designs are summarized in report SL-016181, Rev. 01.
  - Evaluated HTE facilities at 100 MW and 500 MW.
  - A 100 MW<sub>DC</sub> HTE plant requires ≈ 25 MW<sub>th</sub>, while a 500 MW<sub>DC</sub> HTE plant requires ≈ 105 MW<sub>th</sub>.
  - Explored three coupling options. Extracting steam from cold reheat between HP and LP turbines (shown at right) is the preferred option for low levels of steam extraction.
  - Extracting 105 MW<sub>th</sub> from cold reheat decreases PWR output by 22.4 MW<sub>e</sub>.
  - Extracting  $105 \text{ MW}_{\text{th}}$  from main steam decreases PWR output by  $35 \text{ MW}_{\text{e}}$ .
- Design includes a Class 5 cost estimate (-50%, +100%). Estimates include contingencies approximately equal to direct capital costs but exclude financing.
  - Performed estimates for 500 m and 250 m distances between PWR and HTE plants.
  - Standardized cost decreases >3 × as scale of HTE plant increases from 100  $MW_{DC}$  to 500  $MW_{DC}$ .
  - Lowest standardized cost of 61.2/kW<sub>DC</sub> achieved for 500 MW<sub>DC</sub> HTE plant that is 250 from PWR.




	100-MW <sub>DC</sub> , 500-m	500-MW <sub>DC</sub> , 500-m	500- MW <sub>DC</sub> , 250-m
Steam direct cost (\$MM)	6.1	11.7	9.0
Electric direct cost (\$MM)	1.3	1.4	1.2
Indirect & contingency (\$MM)	17.2	26.0	20.4
Total cost (\$MM)	24.6	39.0	30.6
Standardized cost (\$/kW <sub>DC</sub> )	246.0	78.0	61.2

# LWRS

## FY24 Major Research Accomplishments

### **Five Years of Progress:**

- 30-50-70% thermal energy offtake designs and concepts of operations.
- Guidance report on hydrogen production with nuclear power plants.
- Assessment of Gulf Shore hydrogen and thermal markets.
- Prospector tool for screening FPOG markets.
- Value of nuclear power plants relevance to grid reliability and resilience.
- Evaluation of energy arbitrage based on energy storage options.




Completed A/E design and costing for thermal energy extractions:

- 1. Hydrogen production.
- 2. 30, 50, and 70% thermal energy off-take.



Issued LWRS Report: <u>INL/RPT-24-78729</u> *Guidance on Near-Term Hydrogen Production using Nuclear Power* June 2024



Developed simulators and tested operating concepts for PWR and BWR coupled to electrolysis plants.


Completed generic PRA completed for hypothetical nuclearpowered hydrogen plant located near community area.





## **Thermal Energy Extraction and Delivery Accomplishments**

- Designed/evaluated short to medium distance energy delivery systems
- Evaluated thermal energy storage options to supply dynamic energy duties to industry
- Evaluated energy arbitrage storage options
- Completed Class 4 cost projections
- Continued to develop control concepts for energy dispatch
- Addressed safety hazards and licensing options and requirements



March 2024 U.S. Department of Energy Office of Nuclear Energy



# **Sustaining National Nuclear Assets**

lwrs.inl.gov

#### Light Water Reactor Sustainability Program

#### Preconceptual Designs of 50% and 70% Thermal Power Extraction Systems



March 2024 U.S. Department of Energy Office of Nuclear Energy

#### Light Water Reactor Sustainability Program

Flexible Plant Operation and Generation: Hazards and Probabilistic Risk Assessments of a Light-Water Reactor Coupled with Industrial Facilities



September 2024

U.S. Department of Energy Office of Nuclear Energy

Idaho National Laboratory (INL) Battelle Energy Alliance (BEA)

Pre-Conceptual Design for Large-Scale Nuclear Integrated Hydrogen Production Facility

> Report SL-018670 Revision 1 June 21, 2024 Project No.: A14248.015

S&L Nuclear QA Program Applicable:

Yes
No

25 190

55 East Monroe Street Chicago, IL 60603-5780 USA 312-269-2000 www.sargentlundy.com



Report prepared for the Light Water Reactor Sustainability (LWRS) Program at table National Laboratory (IRL) under the direction of Richard Boardman and Tyler Westowe. The views and opinions of authors expressed herein do no necessarily station reflect those of the U.S. Government or any agency thereof. A Human-in-the-Loop Verification of Operating Concepts for a Light-Water Reactor Coupled to a Hydrogen Plant

June 2024 U.S. Department of Energy

Office of Nuclear Energy

Light Water Reactor Sustainability Program

Guidance on Near-Term Hydrogen Production using Nuclear Power

Scenario-based Dual Simulator Thermal Power Dispatch Concept of Operations Evaluation and Demonstration

> Thomas A. Ulrich, Jisuk Kim, Dylan Jurski Idaho National Laboratory Roger Lew, Olugbenga Gideon, Zeth Dubois University of Idaho Kelly Dickerson U.S. Nuclear Regulatory Commission Stephen Hancock GSE Solutions

> > September 2024

Idaho National Laboratory Light Water Reactor Sustainability Idaho Falls, Idaho 83415


http://lwrs.inl.gov



## **Hydrogen Safety Analysis**

### **Detonation Consequences:**

- TNT equivalent method
  - Current standard for the 1.0 psi safe distance in RG 1.91
- Alternate Bauwens method for hydrogen leak jet detonation
  - Hydrogen-specific methodology
  - More precise than TNT equivalence




### Hydrogen Fuel Production Risks

Very difficult to detonate an uncontrolled leak in open air

- Low ignition event frequency
- Lower detonation event frequency

Contained hydrogen can detonate as a cloud

 NFPA standards primary concern is to avoid structures that can contain the hydrogen





## **Hydrogen to Synfuels**

• IES and LWRS 2022 Study

ANL-22/41

### The Modeling of the Synfuel Production Process

Techno-Economic Analysis and Life Cycle Assessment of FT Fuel Production Plants Integrated with Nuclear Power

June | 2022

#### Hernan E. Delgado, Vincenzo Cappello, Pingping Sun, Clarence Ng, Pradeep Vyawahare, Amgad Elgowainy

Systems Assessment Center, Energy Systems and Infrastructure Analysis Division, Argonne National Laboratory




Figure I. Production cost of FT fuel at different plant scales and H<sub>2</sub> prices.