



LWRS Spring Review Meeting

April 27-28, 2025

*Flexible Plant Operations
and Generation (FPOG)*

Richard Boardman - Pathway Lead



Tyler Westover, Jack Cadogan, Paul Talbot – Technical Leads



FPOG research enables diversification of light-water reactors to produce non-electrical products

Flexible Reactor Siting


Data Centers
Manufacturing Plants
Biofuel Plants / Processing
Desalination
Industrial Parks / Plants
Fueling Stations



Research Focus Areas:

- **Technical and economic assessments**
- **Thermal energy offtake and delivery to the second user**
- **Controls & Human Factors**
- **Safety hazards and regulatory review research**


Reference Example



FPOG Topics Presented Today

- 1) Summary of Hydrogen Production Guidance, Risk Assessments, Fire Protection, and License
- 2) High-Capacity Thermal Extraction for Industrial Heating
- 3) Development of End User Tools for Evaluation and Optimization of Resource Expansion and Use

NPP Alternate Energy Stream Research Progression



Progressive Technoeconomic & Market Analysis Research

FPOG 2024/2025 Hydrogen Technical and Economic Assessments

Provision of nuclear heat and electricity for hydrogen & heat delivery to existing industry, maximizing the use of existing infrastructure



H₂ Market Assessment

- H₂ and Heat market opportunities around Light Water Reactors in the Gulf Coast Region.



Business Case Assessment


- Opportunities to produce and **distribute hydrogen and heat** from Gulf Coast NPPs to local industry.
- Techno-economic assessment of options with/without PTC credit.



Yearly Plans

- FY24: Steady State TEA for Hydrogen Production
- FY25: Steady State and Dynamic TEA for Heat delivery vs. H₂ and Electricity Generation.

Identify Potential Hydrogen Demand



Hydrogen Market Analysis Calculator

Process

Outputs

TEA

H₂ Cost Analysis

- LCOH
- H₂ production rate
- IRR
- NPV_{H₂}
- NPV_{BAU*}
- Sensitivity Analysis
- Preference Analysis
- Competitive Analysis



*BAU: Business as Usual

Step-1: Input Specification

HTSE Plant Capacity	HTSE Plant Life	Weighted Average Cost of Capital	Production Tax Credit	NPP Design Power
500 MW-dc	20 Years	12.10%	\$3.00/Kg-H2	538 MW-ac
Hydrogen Market Price(\$2023)	Electricity Price (\$2023)	Natural Gas Price (\$2023)	<small>Note: These inputs parameters are selected based on a pre-sensitivity analysis, where a modular design of 25 MW/module and 0.7312 tonne-H2/hr are assumed. Please click the link to change other input parameters if necessary.</small>	
\$1.00/Kg-H2	\$27.50/MWh	\$4.22/MMBtu		
\$1.00	\$27.50	\$4.22	Fixed: User-defined	

[CLICK: Additional Inputs Information](#)

Step-2: Financial Performance



Tool Information Dashboard Proforma (Market) Elec_NG_Price

Ongoing Equipment and Operational Interface Testing

- Human, and component test with limited scope, pilot-scale coupled thermal and electric power dispatch simulators
 - 150+ kW High Temperature Steam Electrolysis system
 - INL Real-Time Grid Emulator
 - Human Systems Simulation Lab
- Validate simulator predictions and hardware performance

Real-Time Grid Simulator




**High Temperature
Electrolysis
(Bloom 150 kW
Module)**




**Human Systems
Simulation
Laboratory**

Development and Testing of FPOG Operating Concepts




Modified boiling water reactor simulator used in the INL Human Systems Simulation Laboratory




FPOG plant operations concepts testing supported by Westinghouse, GSE, and the University of Idaho

Full-Scope plant simulators were used to successfully test human factors and verify power and steam and be efficiently and safely dispatched to a user connected to the nuclear power plant transmission station.

An Architectural/Engineering company was subcontracted to provide conceptual designs steam and electricity supply to large-scale H₂ plants




A/E pre-conceptual design is being used to estimate costs of hydrogen production and to address safety and licensing consideration




Steam off-take using a reboiler for high temperature electrolysis heating (PWR and BWR plants)

Electrical power take-off from nuclear plant switch yard



100, and 500 MWe modular high temperature steam electrolysis plant layout and piping



Probabilistic Risk Assessment (PRA) to determine hydrogen plant stand-off distance



Probabilistic Risk Assessment Approach


Early simplified PRA approaches

Initiating events, fault trees, FMEA addressed

Steam rupture, fire, explosion,
and other hazards evaluated for
plant operating modes


Qualitative hazards assessment for potential
community and utility business risks

Offset distances to hydrogen
plant from NPP SSCs evaluated




PRA Case: HTEF Interconnect Risk Impact
on NPP Large Steam Line Break Frequency

Comparative HTEF - Licensee Evaluation Approaches



45V Plant-Specific Hydrogen Economics Study (2025 Activity)



Determine credible NPP candidates for hydrogen production based on:

- Regional industrial user hydrogen needs
- Techno-economic analysis of existing generation limits of tax code 45V
- Evaluate the economic feasibility of new generation dedicated to hydrogen through NPP power uprates and restarts

Nuclear Thermal Power Dispatch (TPD) Studies

• Completed


- Integrated 4-loop PWR* – 100 MW_{DC} H₂ facility
- Integrated 4-loop PWR – 500 MW_{DC} H₂ facility
- Integrated BWR* – 500 MW_{DC} hydrogen facility
- 30% TPD from 4-loop PWR (~1,100 MW_t)
- 50% TPD from 4-loop PWR (~1,800 MW_t)
- 70% TPD from 4-loop PWR (2,550 MW_t)

• Participant Roles

- INL: Statement of work and PRA
- S&L: preconceptual design
- Westinghouse: Design basis for control system

*PWR: pressurized water reactor;

*BWR: boiling water reactor



Summary of thermal power destination for 0%, 30%, 50%, and 70% TPD. As TPD increases, condenser duty drops.

- For high levels of thermal power dispatch (TPD) for applications in which high temperature steam is required (>400 °F)

- For lower levels of thermal power extraction or for applications in which low temperature steam is sufficient (<360 °F)

- Both options send steam to a reboiler that condenses secondary steam and generates tertiary steam for dispatch
- Secondary condensate is returned to main condenser




Sargent & Lundy Analysis for 30% & 50% TPD

Nuclear Power Plant Major Equipment Reviewed

- ✓ High Pressure Turbines (HPTs)
- ✓ Low Pressure Turbines (LPTs)
- ✓ Pumps and Condensers
- ✓ Moisture Separator Reheaters (MSRs)
- ✓ Feedwater Heaters (FWHs)
- ✓ Extraction Steam
- ✓ Feedwater Heater Drains
- ✓ MSR Drains


Outcomes

- *For 30% TPD, the analysis shows that the HPT and LPT performance is comparable to ramping reactor down to 75% of thermal output*
- *No major equipment replacements are required*
- *Specific plant components may need minor upgrades and maintenance*



S&L 50% TPD

- Electrical Output ↓ 52%
- Main Steam Flow ↓ 38%
- **Final feedwater temperature drops 52°F**
- **Pressures in Moisture Separator Reheater (MSR)/turbines drop 45%**




Methodology: PEPSE* heat balance models of a reference Westinghouse 4-loop PWR were used to determine the impact on equipment for different levels of TPD

Description	Units	0%	50%	Δ (50%)
Generator Electric Power	MWe	1,228.0	585.3	-52.3%
Thermal Power Extracted	MWt	0	1,827	-
% of Flow - MS	%	0	37.6	-
MS Flow	lbm/hr	16,037,390	14,952,560	-7%
HP Turbine Inlet Flow	lbm/hr	15,218,400	8,615,524	-43%
HP Turbine First Stage Pressure	psia	651.5	374.8	-42%
MSR Inlet Pressure	psia	190.3	104.6	-45%
LP Turbine Inlet Flow	lbm/hr	3,673,069	1,980,267	-46%
LP Turbine Inlet Pressure	psia	175.5	96.43	-45%
Condenser Duty	BTU/hr	8.21E+09	4.18E+09	-49%
Condensate Pump Flow	lbm/hr	11,334,490	11,889,450	4.9%
Heater Drain Pump Flow	lbm/hr	4,732,792	3,093,006	-35%
Feedwater Pump Flow	lbm/hr	16,067,280	14,982,480	-6.8%
Final Feedwater Temperature	°F	440.9	389.0	-51.9°F
Cascading Drain Flow to Condenser	lbm/hr	817,619	670,424	-18%
Cogen HX Inlet Mass Flow	lbm/hr	-	5,629,289	-

*PEPSE: Performance Evaluation of Power Systems Efficiencies by Curtiss-Wright

S&L 50% TPD: General Evaluations

- Small Impacts for 50% thermal extraction
 - ❖ Turbines, MSRs, Pumps, Heater Drain Tanks
- O&M cost concerns for 50% thermal extraction
 - ❖ Feedwater Heaters (FWHs)
 - Flow accelerated corrosion evaluation
 - ❖ Extraction Steam Lines
 - Increased liner thickness requirements
 - ❖ FWH Drain Control Valves (DCVs)
 - Large increases in required flow capacity
 - Would result in automatic opening of the FWH emergency drains




Color Coded Equipment Impacts for 50% Thermal Extraction

S&L 30% & 50% TPD

TPD System

Major Equipment Reviewed

- ✓ Reboilers
- ✓ Flow control valves
- ✓ Stop check globe valve
- ✓ Motor operated isolation valve
- ✓ Piping



Adapted S&L design of TPD line for 500 MW HTEF for 1000 MW HTEF (15% steam extraction). Also tapped off the main steam line.

Outcomes

- Increased Pipe Diameters and Pressure Ratings (Thicknesses)
[or]
- 2 Trains of TPD Line for 30%
- 4 Trains of TPD Line for 50%

Failure Modes and Effects Analysis (FMEA)

Process Function	Hazard/Effect	Potential Causes / Mechanism of failure	Observations
Primary loop for transport of process steam	Loss of steam inventory in the balance of plant	Pipe rupture after main steam isolation valve (MSIV).	Causes loss of steam inventory in the balance of plant if an un-isolated rupture happens before the TPD reboilers. Also results in loss of thermal output to industrial customer.
	Damage to turbine building equipment, possibly safety power buses, depending on the plant	Operational vibration, seismic, and erosion.	Can be resolved by siting the TPD active components in their own building separate from turbine building. It also helps to lower temperature and noise in the turbine building for personnel's comfort and safety.


Probabilistic Risk Assessment (PRA)

Calculation of Initiating Event Fault Tree Additions


- Solver conditions of Systems Analysis Programs for Hands-on Integrated Reliability Evaluations (SAPHIRE)
 - Minimal cutset upper bound ($1.0\text{E-}12$)
 - 10,000 Latin hypercube samples for uncertainty distribution
 - 3,000 Monte Carlo samples for importance measures
- Results
 - Increased frequency per year compared to the original MSLB IE frequency
 - Importance measures: Fussell-Vessely (FV) and Risk Increase Importance (RII)

Probabilistic Risk Assessment (PRA)

Results of Initiating Event Fault Tree Additions



Risk Importance Measures



Overall Conclusions and Next Steps

Overall Conclusions


- A MSLB at 50% thermal energy extraction increases PRA baseline less than 1%
- Additional considerations or adjustments could be made for J2 and P1

Next Steps

- Evaluation of licensing pathways
 - 10 CFR 50.59 (evaluate all eight criteria)
 - If desired, use full PRA results to inform RG 1.174 for changes for further Core Damage Frequency/Large Early Release Frequency risk informed support
- Consideration of condensate return line

Utility Resource Management Process

In the future we will collaborate at this level



FY2025 Demonstration collaborates at this level


- New tools **provide utilities the capability** to assess the benefit of adding integrated energy systems to their portfolio.
- **Resource Planning:** what is the **right size** of IES to couple with existing heat and power to unleash energy resources? What should be the use for downstream products such as hydrogen, water, and heat?
- **Resource Management:** how does an IES help establish **energy resilience** and reliability? How can it free up valuable energy resources?

Demonstration Scenario – Simulation Utility Portfolio

Case 1:
Business as Usual
 - No IES
 - 20 years of operation
 - Hourly dispatch

*Demonstration problem developed
 with feedback from analysts at
 APS, Dominion*

● *Each dot is a single
 generation unit*




Demonstration Scenario – Simulation Utility Portfolio

Case 2 Integrated Energy System (IES)

- End results:
- What size of IES?
 - What is the cost savings?
 - How much is reliability increased?


- 20 years of operation
- CAPEX for IES
 - HTSE 0.1, 0.5, 2 GW
 - Storage 0.1, 0.5, 1 GWh
 - Turbine 0.05, 0.1, 0.5 GW
 - Refine mesh based on results



Example Results

- Identification of energy storage needs for grid balancing by CAISO, ERCOT, PJM
- Optimize generation of required storage capacity to minimize costs and maintain reliability by each generation technology
- Nuclear consistently less expensive due to reduced storage requirements for firm power

Cost (\$/kWh)



In Summary

- 1) FPOG is completing an evaluation of the possibility of producing hydrogen at nuclear plant sites in the United States. Technical, economical, safety evaluations, and regulatory guidance are summarized in an LWRS report.
- 2) High-capacity thermal energy extraction for industrial use is being evaluated based on Sargent & Lundy pre-conceptual design studies; research includes economic assessments for industrial centers, technical/operational impacts, and safety analysis.
- 3) Advanced computation tools are being developed to help utility strategy planners evaluate flexible hybrid systems, resource dispatch and energy storage options
- 4) Future work will explore capacity expansion and increased utilization of nuclear power plants



Sustaining National Nuclear Assets

lwrs.inl.gov